



Miscellaneous technical note B

This technical note has been published to provide information on unintentionally heated cold water, floor wastes and floor waste gullies, flammable insulation in wall cavities and plumbing services in bushfire-prone areas.

Unintentionally heated cold water

The current housing industry practice of installing both heated and cold water pipework in the ceiling space has resulted in reports of unintentional heating of the cold water supply.

Cold water supply pipes exposed to increased ambient temperatures may result in bad tasting drinking water and water wastage as the unintentionally heated water is drawn off from the affected pipework. In some cases, cold water has also been reported at dangerously high temperatures.

Legislation

The issue is currently recognised in the Plumbing Code of Australia 2022 (PCA) under B1P1 Cold water supply installation, as explanatory information only.

AS/NZS 3500.1:2021, clause 5.5.1 has explanatory information in note 4 that installers should consider the negative effects and take precautions to prevent the unintentional heating of cold water pipework.

Solutions and precautions

Possible solutions that should be considered to avoid the unintentional heating of the cold water service would include, but not limited to:

- ▶ Burying the cold water service below ground level.
- ▶ Applying insulation with a suitable 'R' rating to the cold water pipes in ceiling spaces. Note, this may only delay the unintentional heating of the water.
- ▶ Avoiding long runs of unprotected cold water piping in ceiling spaces.
- ▶ Avoid exposed water pipes across roof cladding.
- ▶ Placing batt type insulation over cold water pipes in ceiling spaces.
- ▶ Avoid water pipes on external walls exposed to direct sunlight.

Floor wastes and floor waste gullies

The provisions for floor wastes either, dry untrapped types or floor waste gullies are only mandatory in the following situations:

- ▶ AS/NZS 3500.2:2021, clause 13.24.2.1 requires that the floor of a room containing one or more wall-hung urinals shall grade to a floor waste gully. A dry untrapped floor waste is not permitted.
- ▶ Building Code of Australia (BCA) Volume 1, F2D4 states 'In a Class 2 or 3 building or the Class 4 part of a building, the floor of each bathroom and laundry located at any level above a sole-occupancy unit or public space must be graded to permit drainage to a floor waste'. This can be either a dry untrapped floor waste or a floor waste gully.



Photo 1: Typical floor waste gully for wall hung urinals

AS/NZS 3500.2:2021, clause 13.26 states that untrapped floor drains may be installed in a wet area. That is, they are not compulsory but where they are installed they shall be in accordance with all provisions of the clause.

Untrapped floor wastes shall not connect to floor waste gully risers.

Protection of building elements from wet areas

The BCA, Volume 2 under H4P1 for Class 1 buildings (single dwellings) states that in wet areas, water must be prevented from penetrating behind fittings and linings or into concealed spaces. Examples of acceptable solutions may be the installation of dry untrapped floor wastes, floor waste gullies or using fixtures with integral overflows.

Cavity wall insulation fire risk

A recent incident where flammable wall insulation was ignited has highlighted the need for caution when using tools that produce flames, heat or sparks. A plumber using oxygen/acetylene equipment to repair a leaking copper pipe in a new home ignited the flammable cavity wall insulation.

Insulation is installed in double brick cavity walls in order to achieve an elevated energy efficiency star rating for the building. Unfortunately some of these products are flammable and care should be taken to ensure any work in the vicinity of these combustible materials does not result in a fire.

Precautions

When performing hot works in close proximity to combustible materials the following precautions are recommended:

- ▶ Prior to carrying out hot works, identify any potential combustible materials in close proximity, including reading the manufacturer's material safety data.
- ▶ Temporarily remove and replace combustible material after hot work is completed or take steps to shield any such materials from the source of ignition.

- ▶ Ensure suitable firefighting equipment is available including as a minimum a fire extinguisher of the correct type.

These precautions are particularly important when the ignition of insulation material causes a fire in a position that is difficult to extinguish.

Fire in a cavity wall has the potential to damage electrical wiring and other combustible service pipes and the fire may also spread rapidly into the roof space.

Plumbing services in bushfire-prone areas

When carrying out plumbing work on residential buildings in bushfire-prone areas, licensed plumbing contractors are encouraged to liaise with the builder to ensure any specific requirements that apply to the plumbing installation are met.

The PCA 2022, B1D4 and B2D10 states that cold and heated water services in a designated bushfire-prone area must be in accordance with AS 3959 Construction of buildings in bush-fire prone areas.

All cold and heated above ground exposed water piping shall be metallic.

PCA 2022, C1D4 and C2D5 states that sanitary and drainage systems in areas designated as bushfire-prone must be in accordance with AS 3959.

Vent pipes that penetrate roof sheets shall be non-combustible sealed at the roof. The material used to seal the penetration shall be non-combustible.

Consultation between all parties in the early stages of the building process will minimise the likelihood of the plumbing work being non-compliant and having to be rectified.

Notes

The technical note series is issued by the Plumbers Licensing Board to assist the plumbing industry to comply with the Plumbers Licensing and Plumbing Standards Regulations 2000 (the Regulations) applicable to plumbing work in Western Australia.

Each technical note is to be read in conjunction with Part 6 of the Regulations that currently adopt the Plumbing Code of Australia (PCA) and the deemed to satisfy provisions of AS/NZS 3500:2021, parts 0, 1, 2 and 4 but modified in certain matters to suit the State's building approach and other local conditions.

Copies

Technical notes are published at www.dmirs.wa.gov.au/building-and-energy Printed copies may be made available on request by telephone (08) 6251 1377 or email plumbers.admin@dmirs.wa.gov.au

Disclaimer

The material published by the Department of Mines, Industry Regulation and Safety (Plumbers Licensing Board) is provided voluntarily as a service to the plumbing industry. The information and advice provided is made available in good faith and is derived from sources believed to be reliable and accurate at the time of publication. The information is provided solely on the basis that readers will be responsible for making their own assessment of the matters discussed therein and are advised to verify all relevant representations, statements and information. Changes in circumstances after a document has been published may impact on the accuracy of the information. No assurance is given as to the accuracy of any information or advice contained after publication. This publication may be reproduced or copied without charge for research and educational purposes with due acknowledgement of the source.

© May 2023 Department of Mines, Industry Regulation and Safety