

**ROAM  
CONSULTING**  
ENERGY MODELLING EXPERTISE

ROAM Consulting Pty Ltd  
A.B.N. 54 091 533 621

Report (WEP00015) to



**Appendix A: Results of Analysis of future  
curtailment of wind generation - Original DMO**

Public Version

**17 December 2009**



Report to:



Appendix A: Analysis of future curtailment of wind generation - Additional studies, original DMO

WEP00015  
11 January 2010

## VERSION HISTORY

| Version History |             |                             |                |               |                              |
|-----------------|-------------|-----------------------------|----------------|---------------|------------------------------|
| Revision        | Date Issued | Prepared By                 | Approved By    | Date Approved | Revision Type                |
| 0.5             | 2009-06-03  | Jenny Riesz                 |                |               | Input assumptions            |
| 1               | 2009-06-26  | Jenny Riesz<br>Joel Gilmore | Matthew Holmes | 2009-06-26    | Report                       |
| 1.1             |             | Jenny Riesz<br>Joel Gilmore |                |               | Updated Report               |
| 1.2             | 2009-09-08  | Joel Gilmore                |                |               | Additional Scenarios - Draft |

This report shows the results of analysis performed by ROAM Consulting for System Management. It should be read in conjunction with the System Management report entitled *Effects of increased penetration of intermittent generation in the SWIS*. Note:

- Two versions of the Dispatch Merit Order (DMO) are considered, and the ROAM report detailing the other DMO should be considered.
- Scenarios 1 and 3, which were variants of scenario 2, have been discarded.

## 1) SCENARIOS 2 AND 6 RESULTS

### 1.1) INPUT ASSUMPTIONS

All cogen plant is “must run”, and therefore is the last plant to be decommitted. This includes the following plant:

- Worsley Cogen
- TiWest
- Alcoa Wagerup
- Alinta Pinjara
- Kwinana E
- Alinta Wagerup (once converted)
- Kwinana Cogen Project (PPP\_KCP)
- Mungarra GT1 (must run for voltage support)

All biomass plant is must run.

Selected thermal facilities are also considered must-run:

- Muja 6
- Muja 7
- Muja 8
- Muja A G2
- Muja B
- Collie Power Station
- Bluewaters 1
- Bluewaters 2
- Coal 2 Unit 1
- Coal 1

The above means that 1 out of 4 thermal units are cycled. Therefore the following facilities are cycled (as required):

- All Kwinana thermal units (this is currently occurring)
- Muja A G1
- Muja 5
- Coal 2 Unit 2

### 1.1.1) Commissioning Schedule

| Year Commissioned | Location       | Capacity (MW) | Source data                             |
|-------------------|----------------|---------------|---|
| 2010              | Merredin       | 200           | BOM data (60min data available) 2007-08 |
| 2011              | East of Albany | 100           | Albany wind farm 2007-08                |
|                   | Albany         | 100           | Albany wind farm 2007-08                |
| 2012              | Emu Downs      | 100           | Emu Downs wind farm 2007-08             |
| 2013              | Walkaway       | 100           | Walkaway wind farm 2007-08              |
| 2014              | Albany         | 100           | Albany wind farm 2007-08                |
| 2015              | Emu Downs      | 100           | Emu Downs wind farm 2007-08             |
| 2016              | Walkaway       | 100           | Walkaway wind farm 2007-08              |
| 2017              | Albany         | 100           | Albany wind farm 2007-08                |
| 2018              | Emu Downs      | 100           | Emu Downs wind farm 2007-08             |
| 2019              | Walkaway       | 100           | Walkaway wind farm 2007-08              |

| Year | Plant name            | Market Participant      | Fuel type        | Change in status                |
|------|-----------------------|-------------------------|------------------|---------------------------------|
| 2011 | Kwinana D             | Perth Energy            | Gas              | Commission (1x120MW)            |
|      | Blue Waters 2         | Griffin Power 2 Pty Ltd | Coal             | Commission (1x200MW)            |
|      | Muja A                | Verve Energy            | Coal             | Re-commission (2x60MW)          |
|      | Muja B                | Verve Energy            | Coal             | Re-commission (2x60MW)          |
|      | Kwinana B – LMS100    | Verve Energy            | OCGT- Gas        | Commission (2x100MW)            |
| 2012 | Kwinana A             | Verve Energy            | Thermal          | Retire (2x100MW)                |
| 2013 | OCGT convert to cogen | IPP                     | Gas/Liquid       | Convert OCGT to cogen (2x180MW) |
| 2014 | OCGT 1                | -                       | OCGT- Gas        | Commission (1x180MW)            |
| 2015 | Kwinana E             | -                       | Cogen- OCGT- Gas | Commission (2x180MW)            |
|      | Kwinana C             | Verve Energy            | Thermal          | Retire (2x200MW)                |
| 2016 | Coal 1                | -                       | Coal             | Commission (2x200MW)            |
| 2017 | Coal 2                | -                       | Coal             | Commission (2x200MW)            |

**Table 1.2 – Thermal plant commissioning / retirement schedule – same as Case 2**

| Year | Plant name | Market Participant | Fuel type       | Change in status     |
|------|------------|--------------------|-----------------|----------------------|
| 2018 | New OCGT 1 | -                  | OCGT-Gas/Liquid | Commission (1x180MW) |
| 2019 | New OCGT 2 | -                  | OCGT-Gas/Liquid | Commission (1x180MW) |

## 1.2) WIND CURTAILMENT

Wind curtailment is significantly higher due to the now “must run” coal plant.


**Table 1.3 – Wind Curtailment**

| Year    | Total Installed Wind (MW) | % of Annual wind energy curtailed |            |
|---------|---------------------------|-----------------------------------|------------|
|         |                           | Scenario 2                        | Scenario 6 |
| 2010-11 | 391                       | 0.0%                              | 0.0%       |
| 2011-12 | 591                       | 0.0%                              | 0.7%       |
| 2012-13 | 691                       | 0.0%                              | 1.1%       |
| 2013-14 | 791                       | 0.0%                              | 11.2%      |
| 2014-15 | 891                       | 0.1%                              | 18.0%      |
| 2015-16 | 991                       | 1.0%                              | 28.8%      |
| 2016-17 | 1091                      | 2.9%                              | 42.6%      |
| 2017-18 | 1191                      | 3.9%                              | 48.8%      |
| 2018-19 | 1291                      | 9.3%                              | 56.4%      |
| 2019-20 | 1391                      | 14.9%                             | 61.5%      |


### Curtailment by time of day

Wind farms in overnight periods are completely constrained off, due to demand being met by load following gas plant and must run coal plant. However, even some of the “must run” coal plant is forced to cycle during overnight periods due to the large quantity of load following gas plant online (demonstrated below for Coal IPP and Muja A).

**Figure 1.1a – Wind curtailment in 2019-20 (Scenario 2) – high levels of curtailment**



**Figure 1.2b – Wind curtailment in 2019-20 (Scenario 6) – high levels of curtailment**



Significant curtailment in overnight periods, and moderate curtailment in daytime periods, is now observed.

**Figure 1.3a – Hours of curtailment by time of day (Scenario 2, 2019-20)**






Figure 1.4b – Hours of curtailment by time of day (Scenario 6, 2019-20)




### 1.3) GENERATION




**Figure 1.5 – Energy production in the SWIS (Scenario 6)**




**Figure 1.6 – Energy production in the SWIS (Scenario 2, for comparison)**




### 1.4) GREENHOUSE EMISSIONS



**Figure 1.8 – Greenhouse emissions from the SWIS (Scenario 2, for comparison)**



### 1.5) OPERATIONAL MODES OF PLANTS




Coal fired plant increases generation at the expense of wind and OCGT plant. Capacity factors for load following plant remain relatively unchanged from the original study (Scenarios 1-3).


### Plant cycling

The figures below show periods in both Scenario 2 and Scenario 6 where cycling of coal plants occur. In Scenario 2, cycling occurs on a regular basis.

**Figure 1.10 – Time-sequential generation of coal-fired plant in 2019-20 (Scenario 2)**



**Figure 1.11 – Time-sequential generation of coal-fired plant in 2019-20 (Scenario 6)**



In Scenario 6, several coal power stations are still required to cycle despite their “must-run” status, during periods of high wind/low demand. The large amount of wind combined with the correspondingly large amount of load following gas plant exceeds demand on a regular basis.

## 2) SCENARIOS 4 AND 5 RESULTS

### 2.1) INPUT ASSUMPTIONS

All cogen plant is “must run”, and therefore is the last plant to be decommitted. This includes the following plant:

- Worsley Cogen
- TiWest
- Alcoa Wagerup
- Alinta Pinjara
- Kwinana Cogen Project (PPP\_KCP)
- Mungarra GT1 (must run for voltage support)

All biomass plant is must run.

In Scenario 5, selected thermal facilities are also considered must-run:

- Muja 6

- Muja 7
- Muja 8
- Muja A G2
- Muja B
- Collie Power Station
- Bluewaters 1
- Bluewaters 2

The above means that 1 out of 4 thermal units are cycled. Therefore the following facilities are cycled (as required):

- All Kwinana thermal units (this is currently occurring)
- Muja A G1
- Muja 5

### 2.1.1) Commissioning Schedule

| Table 2.1 – Plant commissioning / retirement schedule |                            |                         |              |  |
|---|----------------------------|-------------------------|--------------|--|
| Year  | Plant name                 | Market Participant      | Plant type   | Change in status   |
| 2009  | Newgen Neerabup            | Newgen                  | OCGT- gas    | Commission (2x165MW)   |
| 2009  | Kwinana Power Station A G1 | Verve Energy            | Thermal      | Reduce maximum capacity from 111.5 to 94.5 MW (ie reduction of 17MW) |
| 2009  | Blue Waters 2              | Griffin Power 2 Pty Ltd | Coal         | Commission (1x200MW)   |
| 2010  | Kwinana D                  | Perth Energy            | OCGT- gas    | Commission (1x120MW)   |
| 2011  | WA Biomass                 | WA Biomass              | Biomass      | Commission (1x40MW)  |
| 2011  | Merriden WF                | Collgar                 | Wind farm    | Commission (1x200MW)   |
| 2011  | Muja A                     | Verve Energy            | Coal         | Re-commission (2x50MW)   |
| 2011  | Muja B                     | Verve Energy            | Coal         | Re-commission (2x60MW)   |
| 2011  | Kwinana B – LMS100         | Verve Energy            | OCGT- gas    | Commission (2x90MW)  |
| 2011  | Kwinana A                  | Verve Energy            | Thermal      | Retire (2x100MW)   |
| 2012  | Biomass 1                  | IPP                     | Biomass      | Commission (1x25MW)  |
| 2012  | OCGT 1                     | IPP                     | OCGT- liquid | Commission (2x125MW)   |
| 2013  | Albany WF2                 | Verve Energy            | Wind farm    | Commission (1x100MW)   |
| 2013  | OCGT 2                     | IPP                     | OCGT- liquid | Commission (2x150MW)   |
| 2014  | OCGT 3                     | IPP                     | OCGT- liquid | Commission (1x100MW)   |
| 2014  | Pinjar 2                   | Verve Energy            | OCGT         | Reduce maximum capacity from 37.2 to 20 MW (ie reduction of 17MW)    |
| 2015  | Biomass 2                  | IPP                     | Biomass      | Commission (2x25MW)  |
| 2015  | EDWF2                      | IPP                     | Wind farm    | Commission (1x100MW)   |
| 2015  | OCGT 4                     | Verve Energy            | OCGT- gas    | Commission (1x150MW)   |

| Year | Plant name  | Market Participant | Plant type   | Change in status     |
|------|-------------|--------------------|--------------|----------------------|
| 2016 | Kwinana C   | Verve Energy       | Thermal      | Retire (2x200MW)     |
| 2016 | Renewable 1 | IPP                | Biomass      | Commission (1x20MW)  |
| 2016 | WWF 2       | Alinta             | Wind farm    | Commission (1x100MW) |
| 2016 | Albany WF 3 | IPP                | Wind farm    | Commission (1x100MW) |
| 2016 | EDWF WF 3   | IPP                | Wind farm    | Commission (1x105MW) |
| 2016 | OCGT 4      | IPP                | OCGT- liquid | Commission (4x150MW) |
| 2016 | OCGT 5      | IPP                | OCGT- liquid | Commission (1x50MW)  |
| 2016 | Pinjar 9    | Verve Energy       | OCGT         | Retire (1x116MW)     |
| 2016 | Pinjar 1    | Verve Energy       | OCGT         | Retire (1x37.2MW)    |
| 2017 | OCGT 6      | IPP                | OCGT- liquid | Commission (2x100MW) |
| 2018 | WWF 3       | IPP                | Wind farm    | Commission (1x55MW)  |
| 2018 | OCGT 7      | IPP                | OCGT- liquid | Commission (1x150MW) |
| 2019 | OCGT 8      | IPP                | OCGT- liquid | Commission (2x100MW) |

### 2.1.2) Assumptions: DMO

Based on current Market Rules.

All biomass should be in the same position as WA Biomass. All OCGT should be in the same position as Alinta Wagerup.

### 2.1.3) Assumptions: minimum capacity

- Removed

|         | Load following required (MW) |
|---------|------------------------------|
| 2010-11 | 62.7                         |
| 2011-12 | 89.0                         |
| 2012-13 | 89.0                         |
| 2013-14 | 105.1                        |
| 2014-15 | 105.1                        |
| 2015-16 | 125.3                        |
| 2016-17 | 198.1                        |
| 2017-18 | 196.1                        |



|         |       |
|---------|-------|
| 2018-19 | 206.2 |
| 2019-20 | 206.2 |

## 2.2) WIND CURTAILMENT


Wind curtailment is significantly higher due to the now “must run” coal plant.


| Year    | Total Installed Wind (MW) | % of Annual wind energy curtailed |            |
|---------|---------------------------|-----------------------------------|------------|
|         |                           | Scenario 4                        | Scenario 5 |
| 2010-11 | 190.7                     | 0%                                | 0.0%       |
| 2011-12 | 390.7                     | 0%                                | 0.0%       |
| 2012-13 | 390.7                     | 0%                                | 0.0%       |
| 2013-14 | 490.7                     | 0%                                | 0.0%       |
| 2014-15 | 490.7                     | 0%                                | 0.0%       |
| 2015-16 | 590.7                     | 0%                                | 0.2%       |
| 2016-17 | 895.7                     | 0%                                | 5.0%       |
| 2017-18 | 895.7                     | 0%                                | 4.5%       |
| 2018-19 | 950.7                     | 0%                                | 5.4%       |
| 2019-20 | 950.7                     | 0%                                | 4.6%       |

### Curtailment by time of day

Wind farms exhibit no constraints under this planting schedule in Scenario 4. Under Scenario 5, with the coal must-run plant, short periods of constraints are observed during early morning periods.


Figure 2.1 – Wind curtailment in 2019-20 (Scenarios 4)






The figure below shows the level of curtailment for each period of the day for Scenario 5. Note, however, that the curtailment level is as a proportion of total wind installed and the chart therefore has a different scale than the Scenario 1-3 and 6 results. Note that Scenario 4 exhibits no wind constraints.

**Figure 2.3 – Hours of curtailment by time of day (Scenario 5, 2019-20)**




## 2.3) GENERATION

**Figure 2.4 – Energy production in the SWIS (Scenario 4)**



**Figure 2.5 – Energy production in the SWIS (Scenario 5)**



## 2.4) GREENHOUSE EMISSIONS

Emissions are similar in both scenarios, remaining relatively constant over the duration of the study.






Figure 2.7 – Greenhouse emissions from the SWIS (Scenario 5)



## 2.5) OPERATIONAL MODES OF PLANTS


**Figure 2.8 – Capacity Factors of plants in the SWIS (Scenarios 4 and 5)**






## Plant cycling

**Figure 2.9 – Time-sequential generation of coal-fired plant (Scenario 4)**





In Scenario 4, coal fired plant is required to cycle occasionally (as in the case of Muja C above, shown for both Scenario 4 and Scenario 5 for comparison). In Scenario 5, the wind is curtailed first in every period and no cycling occurs. The generation is also spread more evenly between stations.

### 3) FUEL USAGE

ROAM has estimated the fuel usage for each year of each scenario. ROAM has determined best estimates for heat rates for plants in the SWIS and has calculated fuel usage accordingly (in petajoules). The figures below refer to fuel used during operation at typical levels and do not include fuel required for plant start-ups, e.g., for cycling coal plant. As such, these figures may be underestimates of true SWIS fuel usage.

**Figure 3.1 – Fuel usage (PJ)**

|            |        | 2010-11 | 2011-12 | 2012-13 | 2013-14 | 2014-15 | 2015-16 | 2016-17 | 2017-18 | 2018-19 | 2019-20 |
|------------|--------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| Scenario 2 | Gas    | 55      | 59      | 56      | 54      | 59      | 56      | 57      | 57      | 58      | 55      |
|            | Liquid | 5.6     | 3.0     | 3.5     | 2.2     | 1.9     | 1.9     | 1.0     | 0.4     | 10.5    | 24.1    |
|            | Coal   | 110     | 109     | 111     | 99      | 89      | 78      | 74      | 75      | 67      | 59      |
| Scenario 4 | Gas    | 47      | 49      | 50      | 51      | 52      | 59      | 63      | 64      | 65      | 66      |

|            |        |     |     |     |     |     |     |     |     |      |      |
|------------|--------|-----|-----|-----|-----|-----|-----|-----|-----|------|------|
|            | Liquid | 2.4 | 2.0 | 2.3 | 2.9 | 3.6 | 3.3 | 4.6 | 5.4 | 5.8  | 6.5  |
|            | Coal   | 125 | 121 | 123 | 125 | 127 | 123 | 109 | 111 | 109  | 111  |
| Scenario 5 | Gas    | 47  | 49  | 50  | 51  | 52  | 59  | 63  | 64  | 65   | 66   |
|            | Liquid | 2.4 | 2.0 | 2.3 | 2.9 | 3.6 | 3.3 | 4.6 | 5.4 | 5.8  | 6.5  |
|            | Coal   | 125 | 121 | 123 | 125 | 127 | 123 | 110 | 112 | 111  | 113  |
| Scenario 6 | Gas    | 55  | 59  | 56  | 54  | 59  | 56  | 57  | 57  | 58   | 55   |
|            | Liquid | 5.6 | 3.0 | 3.5 | 2.2 | 1.9 | 1.8 | 1.0 | 0.4 | 10.5 | 24.1 |
|            | Coal   | 110 | 109 | 111 | 102 | 95  | 86  | 88  | 94  | 88   | 81   |

As expected, requiring coal plants to be must-run significantly increases the coal fuel usage, generally at the expense of wind generation so that gas and liquid usage is not significantly affected.

