

Intermittent generation- Results of ROAM studies

October 2009

Presenter: Matthew Fairclough


Analyses performed

- Scenarios:
 - Wind: high and low
 - Must-run generation: higher and lower
- Scenarios:
 - 2: high wind, lower must-run
 - 4: low wind, lower must-run
 - 5: low wind, higher must-run
 - 6: high wind, higher must-run
 - (scenarios 1 + 3 were minor variations of scenario 2)
- Two dispatch merit orders used:
 - Market Rules used based
 - Cost-reflective
- Must-run identified on basis of Power System Security.
 - Biomass plant also considered must-run.
- All wind assumed to be located in Merriden, Albany, Emu Downs and Walkaway
 - 2007-08 wind was used for all years
- This is one possible model that only considers known technologies
 - Did not consider: economic modeling for new capacity, network constraints, or CPRS.


RET Target

- National RET Target for 2020: 45,000 GWh
- Predicted SWIS energy for 2020: ~24,840 GWh
- Predicted national demand in 2020: ~292,000 GWh
- WA RET requirement: ~ 3830 GWh = 15.4%
- The requirement is not 20% of energy in 2020.

Assumptions- Demand




Assumptions- New capacity




Low wind ← → High wind

Assumptions- Total capacity



Assumptions- Must-run generation



Load Following definition


- Load Following Service is the service of frequently adjusting the output of one or more Scheduled Generators within a Trading Interval so as to match total system generation to total system load in real time in order to correct any SWIS frequency variations [MR 3.9.1].
 - LF facilities must be able to quickly ramp up or down to maintain frequency at 50 Hz.
- The standard for Load Following Service is a level which is sufficient to provide Minimum Frequency Keeping Capacity, which is the greater of 30 MW and the capacity sufficient to cover 99.9% of the short term fluctuations in load and output of Non-Scheduled Generators and uninstructed output fluctuations from Scheduled Generators, measured as the variance of 1 minute average readings around a thirty minute rolling average [MR 3.10.1].
 - LF is a +/- value.
 - For Power System Security purposes, a ramp-rate requirement is also determined, giving a minimum ramp rate for plants providing LF.
- Included in quantum of Spinning Reserve (SR) [MR 3.10.2].
- SM must dispatch facilities to ensure that LF (and SR) are maintained *at all times*.

Load Following effects on operation

- Load Following (LF) can only be provided by flexible GT's with a high ramp-rate ($> 5\text{Mw/min}$).
- Thermal facilities (eg coal) are not flexible enough to provide LF.
- For every facility providing LF:
 - Maximum amount of LF available is half the difference between minimum and maximum generation
 - Eg If max gen cap=100 MW and min gen cap= 20 MW, then available LF= +/- 40 MW
 - Must-run generation increases by more than the Load Following requirement.


High wind scenario- Load Following requirement

ROAM
CONSULTING
ENERGY MODELLING EXPERTISE




Low wind scenario- Load Following requirement


ROAM
CONSULTING
ENERGY MODELLING EXPERTISE




Results- Energy production in the SWIS- Market Rules based DMO




Results- Energy production in the SWIS- Cost-reflective DMO




Results- Total renewable energy for Market based DMO




Results- Greenhouse emissions- Market Rules based DMO




Results- Greenhouse emissions Cost-reflective DMO





Results- Capacity factors- Market Rules based DMO



Low wind ← System Management → High wind



Results- Capacity factors- Cost-reflective DMO





Results- Wind curtailment

Both DMO's


	Scenario	4	5		Scenario	2	6
	Wind	Low	Low		Wind	High	High
	Must-run	Low	High		Must-run	Low	High
Year	Total Installed Wind (MW)	% of Annual wind energy curtailed			Total Installed Wind (MW)	% of Annual wind energy curtailed	
2010-11	190.7	0.00%	0.00%		391	0.00%	0.00%
2011-12	390.7	0.00%	0.00%		591	0.00%	0.70%
2012-13	390.7	0.00%	0.00%		691	0.00%	1.10%
2013-14	490.7	0.00%	0.00%		791	0.00%	11.20%
2014-15	490.7	0.00%	0.00%		891	0.10%	18.00%
2015-16	590.7	0.00%	0.20%		991	1.00%	28.80%
2016-17	895.7	0.00%	5.00%		1091	2.90%	42.60%
2017-18	895.7	0.00%	4.50%		1191	3.90%	48.80%
2018-19	950.7	0.00%	5.40%		1291	9.30%	56.40%
2019-20	950.7	0.00%	4.60%		1391	14.90%	61.50%

Results- Coal starts (high wind, lower must-run, Market based DMO)



For Power System Security this is not technically feasible.



Results- Fuel usage Market Rules based DMO



Results- Fuel usage Cost-reflective DMO



Conclusions

- The results are largely identical using a Market based or cost-reflective DMO.
- As wind penetration increases, a threshold will be reached where operational issues occur solely due to wind variation.
- High wind scenario results in significantly lower emissions. Low wind scenario does not decrease emissions much.
- In each scenario, as wind penetration increases the Load Following requirement increases adding a significant must-run burden.
- As must-run plant increases, wind-curtailment and cycling of coal plant increases due to low overnight loads.
- High amounts of wind with moderate/high amounts of must-run plant result in significant wind-curtailment and significant (probably untenable) cycling of coal plant.
- Only the high wind scenario meets the RET target.
- With high wind and moderate/high amounts of must-run plant capacity factors of coal plants decrease from 70% to 30%, and cycling of Verve/IPP coal plants rise to once a day (which is not feasible for Power System Security).